



C.NO/137/FSCR/DFO/BELAGAVI/2025

Date : 26-09-2025

To,
The Principal
Ekalavya Model Residential School (EMRS)
Tavaga, Gokak Taluk, Belagavi District.

Sir,

Sub: Issue of "Fire Safety Compliance Report" to Ekalavya Model Residential School (EMRS), Tavaga, Gokak Taluk, Belagavi District.

Ref:- 1) C.NO/137/ADV/DFO/BELAGAVI/2025 Date: 26-08-2025.
2) Applicant Request Letter Date: 17-09-2025.

*_*_*_*_*_*_*_*_*_*

With reference to the subject above cited, the premises of Ekalavya Model Residential School (EMRS), building consisting with Ground Floor situated at Tavaga, Gokak Taluk, Belagavi District was inspected by District Fire Officer Belagavi on 20-09-2025 with respect to fire Prevention, Fire Fighting & Evacuation point of view for the purpose of issuing Fire Safety Compliance Report and has submitted the details as under.

ANNEXURE-1

(Up to 14.99 mtrs. In height) GROUP-B Educational Buildings

NBC-2016, Part-4, Table 7 (11) 3.1.3 Group B Educational Buildings Sub division B1 & B2.
(These condition are indicative and not exclusive all relevant provisions related to fire and life safety of NBC 2016 are mandatory.)

A. Details of the Building/Premises.

01.	Name and Address of the Applicant	The Principal Ekalavya Model Residential School (EMRS) Tavaga, Gokak Taluk, Belagavi District.
02.	Name and Address of the Premises	Ekalavya Model Residential School (EMRS) Tavaga, Gokak Taluk, Belagavi District.
03.	Name and Address of the Building Owner	The Principal Ekalavya Model Residential School (EMRS) Tavaga, Gokak Taluk, Belagavi District.
04.	Number of Building	01
05.	Number of Floors	Ground Floor
06.	Floor-wise details of Occupancy:- Ground Floor	Class Room-06, Office Room-01, Computer Room-01, Lab Room-03, Store Room-01, Warden Room-01 & Sports Room-01.
07.	U-Dise Number	29300609608
08.	Height of the building	03.95 Mtr
09.	Site area	25 Acres 16 Gunta
	Built-up area of each floor:- Ground Floor	1510.63 Sq ft
11.	Total Built-up area	1510.63 Sq ft

12.	Surrounding properties:-	
	East	06.00 mtr road
	West	Forest Open land
	North	Open land
13.	Open Space all around the building	
	East	Nil
	West	05.00 mtr
	North	10.00 mtr
	South	03.00 mtr
Allowed Setbacks (open space) should be maintained free from further obstruction/construction.		

B. On the inspection of this School/College premises, the following Fire Prevention, Fire Fighting and Evacuation Measures recommended are considered absolutely essential from fire safety point of view:-

S.No (01)	Details (02)	Existing (03)	Recommendations (04)
01.	Accessibility to the premises	The premises is accessible from 06.00 mtr wide road on the Eastern Side	Adequate
02.	Number of Entrances	01 No. of 4.60 wide & 03.60 Height on Eastern Side.	Adequate
03.	Portable Extinguishers	06 nos. of 6 Kg capacity ABC type & 01 no. of 4.5 Kg capacity CO2 type extinguishers has been provided. All the extinguishers suggested are BIS markings and are located at an easily accessible position without obstructing the normal passage.	Complied
04.	Escape routes	Direction in which the students/teachers have to move in the event of emergency have been indicated in the corridor/passage as a guide during evacuation .	Complied.
05.	Fire Order (Fire safety plans)	A notice board indicating the action to be taken by the employees in case of any emergency have been displayed along with the telephone numbers of Gokak Fire station i.e 08332-225011, 101 & 080-22971550, 22971500, 22971600 the telephone nos nearest ambulance services and police station.	Complied
06.	No Smoking board	COPTA Sec-4 direction of No Smoking area, smoking here is an offence board is written in the English & Kannada both languages and is displayed inside the entry/exit of the each floor.	Complied
07.	Fire Fighting Training	02 persons have undergone basic fire fighting training at Amargol Fire Station Hubballi premises. From 07-07-2025 to 08-07-2025	At least 40% of the Teaching and non Teaching staff should be got trained in basic fire fighting at R.A.Mundkur Fire & Emergency Services Academy

Handwritten signature and date: 26/11/25

	1) Sri. Shivashankar Mangoji 2) Sri. Harigovind Chauhan	Bannerughatta Road, Bangalore or Regional training centre.
08.	<p><u>Fire Precautionary Measures</u></p> <p>A :- Explosive and flammable materials should not be stored in the store room, UPS room, Electrical panel area, class rooms, laboratory and electrical sum panel premises.</p> <p>B:- Accumulation of combustible waste in and around the premises should be avoided.</p> <p>C:- The Exit ways shall be always kept clear without any obstruction.</p> <p>D:- Liquefied petroleum gas should not be stored in the building.</p> <p>E:- The doors shall not be kept locked/ latched during working hours and shall be free from obstruction.</p> <p>F:- During the class hours the class room door shall not be locked from inside to out side.</p> <p>G:- As per Honorable Supreme Court order all teachers and staff shall be trained to handle safety equipments, initiate emergency evacuation and protect their students in the event of fire and other emergency and the school hall observe the Fire Safety Day on April 14th of every year by conducting Fire Safety drills with co-ordination with the fire services department.</p>	

Under the above circumstance the Karnataka Fire & Emergency Services Department is issuing "Fire Safety Compliance Report" to Ekalavya Model Residential School (EMRS), Tavaga, Gokak Taluk, Belagavi District. As they have complied all the recommendations as per reference 1. The staff should get trained in the basic fire fighting at R.A.Mundkur Fire & Emergency Services Academy, Bannerughatta Road, Bangalore or Regional training centre Hubballi.

This "Fire Safety Compliance Report" is valid for only one year from the date of issue and is renewable.

Yours Faithfully


District Fire Officer 26/9/28
Karnataka State Fire And Emergency Services
Belagavi-01.

FIRE SAFETY CERTIFICATE

No: 137/FSCR/DFO/BELAGAVI/2025

Date: 26-09-2025

Certified that the Ekalavya Model Residential School (EMRS), Tavaga, Gokak Taluk, Belagavi District. Comprised of Zero Basement and Ground Floor Owned/Occupied by Ekalavya Model Residential School (EMRS), Tavaga, Gokak Taluk, Belagavi District. Have complied with the fire prevention and fire safety requirements in accordance with rule of State/UT Fire Service Rules, and verified by the District Fire Officer Belagavi Fire Service on 20-09-2025 in the presence of The Principal, Sri. Mahendra Singh and that the Building/Premises is fit for occupancy upto classes Xth with effect from 20-09-2025 for a period of One Year in accordance with rule and subject to compliance of specific conditions as appended:-

1. Maintenance of all fire fighting installations periodically
- 2.
- 3.
- 4.

Issued on 20-09-2025 at Belagavi, by

*Strike out whichever is not applicable.


 District Fire Officer 26/9/25
 Karnataka State Fire And Emergency Services
 Belagavi-01.....
 Signature with Seal :
 Name : Ranganath
 Designation : District Fire Officer
 Name & Address : Office of the District Fire Officer
 of Department/Office : Office of the District Fire Officer
 Karnataka State Fire & Emergency
 Services, Khanapur Road, Near
 Goaves Circle, Belagavi-590001.

To,
 The Principal
 Ekalavya Model Residential School (EMRS)
 Tavaga, Gokak Taluk, Belagavi District.

ENDORSEMENT

The No Objection Certificate issued by Fire Service stand cancelled an annulled due to

.....

.....

(Name and Designation of the authorized signatory)

*The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with original vernacular certificate as a single pdf.